

Load Test Result (BMS)

Site Name Energic Plus Concept
 Site Code Laborator
 Province Ag

Test Date 7/21/2017 6:51:16 PM
 Test Time 47:03:00
 MCS NO. 72014

Brand	ISKRA			Volt.	24	Ah	240	Cells	12	Standby Volt.	26.1	Type	Pb-Ac	Year/Manuf.	2006	Ambient Temp.	27	
Time	#1	#2	#3	#4	#5	#6	#7	#8	#9	#10	#11	#12						Sum
00:00	2.14	2.15	2.14	2.16	2.16	2.16	2.16	2.13	2.15	2.14	2.14	2.16						25.79
00:15	2.06	2.05	2.05	2.07	2.06	2.07	2.06	2.04	2.05	2.04	2.06	2.06						24.67
00:30	2.06	2.05	2.05	2.06	2.06	2.07	2.06	2.03	2.05	2.04	2.06	2.06						24.65
00:45	2.06	2.05	2.04	2.06	2.06	2.06	2.06	2.03	2.05	2.04	2.05	2.05						24.61
01:00	2.06	2.04	2.04	2.05	2.05	2.06	2.05	2.03	2.04	2.04	2.05	2.05						24.56
01:15	2.05	2.04	2.04	2.05	2.05	2.05	2.05	2.02	2.04	2.03	2.04	2.05						24.51
01:30	2.05	2.03	2.03	2.05	2.05	2.05	2.05	2.02	2.04	2.03	2.04	2.04						24.48
01:45	2.04	2.03	2.03	2.04	2.04	2.05	2.04	2.01	2.03	2.02	2.03	2.04						24.40
02:00	2.04	2.03	2.03	2.04	2.04	2.04	2.04	2.01	2.03	2.02	2.03	2.03						24.38
02:15	2.03	2.02	2.02	2.03	2.03	2.04	2.03	2.01	2.02	2.02	2.02	2.03						24.30
02:30	2.03	2.02	2.02	2.02	2.03	2.03	2.03	2	2.02	2.01	2.02	2.02						24.25
02:45	2.02	2.01	2.01	2.02	2.02	2.03	2.03	2	2.02	2.01	2.01	2.02						24.20
03:00	2.02	2.01	2.01	2.01	2.02	2.02	2.02	1.99	2.01	2	2.01	2.01						24.13
03:15	2.01	2	2	2.01	2.02	2.01	2.02	1.99	2.01	2	2	2.01						24.08
03:30	2.01	2	2	2	2.01	2.01	2.01	1.98	2	1.99	1.99	2						24.00
03:45	2	1.99	1.99	1.99	2.01	2	2.01	1.97	2	1.99	1.99	1.99						23.93
04:00	1.99	1.99	1.99	1.99	2	2	2	1.97	1.99	1.98	1.98	1.99						23.87
04:15	1.99	1.98	1.98	1.98	1.99	1.99	2	1.96	1.99	1.98	1.97	1.98						23.79
04:30	1.98	1.98	1.98	1.97	1.99	1.98	1.99	1.95	1.98	1.97	1.96	1.97						23.70
04:45	1.97	1.97	1.97	1.97	1.98	1.98	1.98	1.95	1.97	1.97	1.96	1.97						23.64
05:00	1.97	1.96	1.97	1.96	1.98	1.97	1.98	1.94	1.97	1.96	1.95	1.96						23.57
05:15	1.96	1.96	1.96	1.95	1.97	1.96	1.97	1.93	1.96	1.96	1.94	1.95						23.47
05:30	1.95	1.95	1.95	1.94	1.96	1.95	1.97	1.92	1.96	1.95	1.93	1.95						23.38
05:45	1.94	1.95	1.95	1.93	1.96	1.94	1.96	1.92	1.95	1.94	1.92	1.94						23.30
06:00	1.93	1.94	1.94	1.93	1.95	1.93	1.95	1.91	1.94	1.94	1.9	1.93						23.19
06:15	1.92	1.93	1.94	1.92	1.94	1.92	1.95	1.9	1.93	1.93	1.89	1.92						23.09
06:30	1.91	1.92	1.93	1.9	1.94	1.91	1.94	1.88	1.93	1.92	1.87	1.91						22.96
06:45	1.9	1.91	1.92	1.89	1.93	1.9	1.93	1.87	1.92	1.91	1.85	1.9						22.83
07:00	1.89	1.9	1.91	1.88	1.92	1.88	1.92	1.85	1.91	1.9	1.83	1.89						22.68
07:15	1.87	1.89	1.9	1.86	1.91	1.86	1.92	1.84	1.9	1.89	1.78	1.87						22.49
07:30	1.85	1.88	1.89	1.85	1.9	1.83	1.91	1.82	1.89	1.88	1.69	1.86						22.25
07:39	1.84	1.88	1.89	1.84	1.89	1.81	1.9	1.8	1.88	1.88	1.6	1.85						22.06

