

Load Test Result (MCS)

Site Name Energic Plus Concept
 Site Code Laborator
 Province Ag

Test Date 2/10/2017 3:14:19 PM
 Test Time 30:46:19 / 54:00:00
 MCS NO. F11510072014

Brand	Hawker	Volt.	48	Ah	620	Cells	24	Standby Volt.	48	Type	Le-Ac	Year/Manuf.	2005 02	Ambient Temp.	15
-------	--------	-------	----	----	-----	-------	----	---------------	----	------	-------	-------------	---------	---------------	----



Index	Method	Pulse	Setup Time	Elapsed Time	Setup Volt	Max Volt	Min Volt	Setup Amp	AH	Temperature
1	Discharge	1	12:00:00	01:55:38	41.3	51.5	41.3	68.2	-131.3	+029
2	Restoration	1	06:00:00	01:41:05	60.4	60.4	45.1	68.2	114.6	+034
3	Restoration	4	08:00:00	08:00:00	62.4	60.0	51.5	15.0	30.1	+028
4	Restoration	2	08:00:00	08:00:00	62.4	62.5	53.4	34.1	212.7	+046
5	Discharge	1	12:00:00	03:09:36	41.3	58.9	41.3	68.2	-215.6	+044
6	Restoration	2	08:00:00	08:00:00	62.4	62.5	46.5	68.2	307.9	+050

30:46:19