


Load Test Result (MCS)

Site Name Energic Plus Concept
 Site Code Laborator
 Province Ag

Test Date 21/12/2017 16:00:28
 Test Time 42:18:13 / 54:00:00
 MCS NO. 72014

Brand	Haulotte Star 10	Volt.	24V	Ah	240Ah	Cells	12x2V	Standby Volt.	24V	Type	Pb-Ac	Year/Manuf.	N.A.	Ambient Temp.	19C
-------	------------------	-------	-----	----	-------	-------	-------	---------------	-----	------	-------	-------------	------	---------------	-----



Index	Method	Pulse	Setup Time	Elapsed Time	Setup Volt	Max Volt	Min Volt	Setup Amp	AH	Temperature
1	Discharge	1	12:00:00	05:30:25	20.6	25.1	20.6	26.4	-145.9	+023
2	Restoration	2	06:00:00	06:00:00	29.2	28.9	22.1	26.4	159.0	+031
3	Restoration	4	08:00:00	08:00:00	31.2	29.4	25.9	15.0	31.7	+027
4	Restoration	2	08:00:00	08:00:00	31.2	29.5	26.9	13.2	106.2	+040
5	Discharge	1	12:00:00	07:32:28	20.6	28.4	20.6	26.4	-199.8	+030
6	Restoration	2	08:00:00	07:15:20	31.2	29.4	22.2	26.4	192.1	+038

42:18:13